

The City of Hubbard Drinking Water Consumer Confidence Report for 2020

Introduction

The City of Hubbard has prepared the following report to provide information to you, the consumer, on the quality of its drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts. In 2020, the city of Hubbard had a current valid unconditional license to operate a public water system. PWSID: OH7801415.

Source Water Information

The City of Hubbard does not own a water treatment facility. Treated water is purchased from Aqua Pennsylvania and distributed by the City of Hubbard. The source water is the Shenango River fed from the Pymatuning and Shenango Reservoirs. The plant is located 3.5 miles downstream of the Shenango Reservoir outfall (refer to map located at the end of this report). Treatment includes purification and disinfection to destroy potential pathogenic organisms. "For the purposes of source water assessments, in Ohio all surface waters are considered to be susceptible to contamination. By their nature, surface waters are readily accessible and can be contaminated by chemicals and pathogens which may rapidly arrive at public drinking water intakes with little warning or time to prepare." For more information on source water assessment please contact Aqua PA Shenango PA at 724.347.7418

What are Sources of Contamination to Drinking Water?

The sources of tap and bottled drinking water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the land or through the ground, it dissolves minerals, and in some cases, radioactive material, and can pick up substances resulting from animal presence or human activity. Contaminants that may be present in source water include: (A) Microbiological contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production, and mining activities. In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791

Who Needs to Take Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

Tests performing by City of Hubbard or Aqua Pennsylvania- Please check under each contaminant for responsible party Listed is information on contaminants found in sample collected by Aqua Pennsylvania:

Entry Point Disinfectant Residual								
Contaminants	Minimum Level Found	Minimum Disinfectant Residual	Range of Detection	Sample Date	Violation Y/N	Major Sources in Drinking Water	MRDL PPM	MRDLG PPM
Total Chlorine, ppm Aqua PA	1.0	0.2	1.0-3.4	2020	N	Water additive used to control microbes	4.0	4.0
Chlorine Dioxide, ppm (entry point) Aqua PA	0*	0.2	ND-0.17	2020	N	Water additive used to control microbes	4.0	4.0
Total Chlorine ppm City of Hubbard	1.5	1.0	1.5-2.0	2020	N	Water additive used to control microbes	4.0	4.0

Contaminants	Level Found	Range of Detections	MCL	MCLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
Turbidity, % meeting plant performance level Aqua PA	99.7%	99.7-100.0%	TT	NA	2020	N	Soil runoff
Turbidity, NTU Aqua PA	0.20	0.02-0.20	TT	NA	2020	N	Soil runoff
Total Organic Carbon Removal Ratio Aqua PA	1.00	1.00-1.40	≥ 1.00, TT	NA	2020	N	Naturally present in the environment
Inorganic Compounds							
Barium, ppm Aqua PA	0.016	NA	2	2	2020	N	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Fluoride, ppm Aqua PA	.91	0.08-1.10	2	2	2020	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate, ppm Aqua PA	.85	ND-.85	10	10	2020	N	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Disinfection Byproducts- For Haloacetic Acids and Total Trihalomethanes, the Level Found is the highest annual average of the quarterly averages. Compliance is based on a running annual average of quarterly results, not a single sample. The Range of Results lists the highest and lowest values among all individual samples.							
Haloacetic acids, ppb City of Hubbard	44.9	15.8-44.9	60	NA	2020	N	Byproduct of drinking water chlorination
Total Trihalomethanes, ppb City of Hubbard	65.8	19.6-65.8	80	NA	2020	N	Byproduct of drinking water chlorination
Chlorite, ppm (distribution system) Aqua PA	0.39	ND-0.55	1	0.8	2020	N	Byproduct of drinking water chlorination
Chlorite, ppm (entry point) Aqua PA	1.23	ND-1.23	1	0.8	2020	N	Byproduct of drinking water chlorination

About Your Drinking Water

The EPA requires regular sampling to ensure drinking water safety. Aqua Pennsylvania conducted sampling for bacteria, inorganic, radiological, synthetic organic, and volatile organic contaminants in 2020. The majority of the samples collected were below the limit of detection. The Ohio EPA requires water suppliers to monitor for some contaminants less than once per year because the concentration of these contaminants do not change frequently. Some of our data, though accurate, may be more than one year old. The City of Hubbard Water Department conducts testing within the distribution system. Regular samples are taken for bacteria, trihalomethanes, and haloacetic acids.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with water service lines and home plumbing. Aqua Pennsylvania is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. A list of laboratories certified in Ohio to test for lead may be found at www.epa.state.oh.us/ddagw or by calling 614-644-2752. Information on lead in drinking water, testing methods, and steps you can take to minimize exposures is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Monitoring for cryptosporidium (a naturally occurring microbial pathogen) was conducted under a national program in 2009 on untreated water samples from Aqua’s source, the Shenango River. Aqua’s water treatment processes are designed to remove cryptosporidium, but complete removal of all organisms at all times cannot be guaranteed. For this reason, immuno-compromised individuals (people with weakened immune systems) are encouraged to consult their doctor regarding appropriate precautions to avoid infection.

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every five years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR4 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of UCMR4 monitoring in 2018 from Aqua Pennsylvania. All other contaminants tested during UCMR4 were Not Detected

Lead and Copper	MCLG	Action Level	Individual Results over the AL	90% of tests levels were less than	Sample Date	Violation Y/N	Major Sources in Drinking Water
Copper ppm City of Hubbard	1.3	1.3	NA	0.26	2020	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Zero out of 20 samples were found to have copper levels in excess of the copper action level of 1.3 ppm							
Lead ppb City of Hubbard	0	15	NA	<2.0	2020	N	Corrosion of household plumbing systems; Erosion of natural deposits
Zero out of 20 samples were found to have lead levels in excess of the lead action level of 15 ppb							

Turbidity is a measure of the cloudiness of the water and is an indication of the effectiveness of our filtration system. The turbidity limit set by the EPA is 0.3 NTU in 95% of the samples analyzed each month and shall not exceed 1 NTU at any time. As reported above, the .24 NTU’s highest recorded turbidity result for 2019 was highest recorded turbidity NTU.

The value reported under “Level Found” for Total Organic Carbon (TOC) is the lowest ratio between percent of TOC actually removed to the percentage of TOC required to be removed. A value of greater than one (1) indicates that the water system is in compliance with TOC removal requirements. A value of less than one (1) indicates a violation of the TOC removal requirements.

How do I participate in decisions concerning my drinking water?

Public participation and comments are encouraged at the City of Hubbard regular Council meetings. Meetings are held the first and third Monday every month at 7:00 pm at City Hall Council Chambers.

For more information, or a copy of this report, contact:

George Ginnis at 330-534-3636. Copies of this report are also available in the Mayor's Office, City Hall, 220 West Liberty Street, Hubbard, Ohio 44425 330-534-3090.

Definitions and Terms Contained Within This Report:

Maximum Contaminant Level Goal (MCLG):The level of a contaminant in drinking water below which there is no known or expected risk to health.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Parts per Million (ppm) or Milligrams per Liter (mg/l): Units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per Billion (ppb) or Micrograms per liter (ug/l): Units of measure for concentration of a contaminant. A part per billion corresponds to one second in over 31.7 years.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

ND: Not Detect Maximum Residual Disinfectant Level

(MRDL): The highest residual disinfectant level allowed.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of residual disinfectant below which there is no known or expected risk to health.

PFAS: Per- and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them waterproof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of firefighting foam called aqueous film forming foam

(AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.